

**COLLIER COUNTY GOVERNMENT**  
**GROWTH MANAGEMENT DEPARTMENT / BUILDING REVIEW & INSPECTION DIVISION**  
2800 N. Horseshoe Drive, Naples FL 34104 \* Phone (239) 252-2428

## Outstanding Corrections

**Date:** February 27, 2023  
**Contact Name:** Adam Ahmad - Capital Contractors  
**Address:** 9010 Strada Stell Ct, Suite 108  
**City, State Zip:** Naples, FL 34109

**PERMIT NO:** PRSD2023010072201  
**APPLICATION NO:** PRSD20230100722  
**JOB SITE ADDRESS:** 3335 Tamiami TRL E W, (BLDG) ,  
Naples  
**Email:** kellyahmad@capitaldesignbuild.com; adam.ahmad@capitalengr.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

***For Applications Submitted through the GMD E-Permitting Portal:***

- Resubmittals must be submitted in the same session and the changes must be clouded.
- Corrected documents must be submitted as complete files (with the corrected sheets *replacing* the rejected sheets). Submittals containing just the corrected sheets will be returned as Insufficient.
- **A written letter of response summarizing the changes made to address each correction comment must be included in your resubmittal. Failure to include a written letter of response will result in a rejection.**
- After your resubmittal is processed the documents will be reviewed again; additional deficiencies may be identified through this process.

**JOB DESCRIPTION:** Remove and replace one door and frame.

3335 Tamiami TRL E W, (BLDG) , Naples

**Rejected Review: Structural Review**  
**Reviewed By: Lisa Blacklidge**  
**Phone: 239-252-2758    Email: Lisa.Blacklidge@colliercountyfl.gov**

Correction Comment 1: FBC-B 7th 2020 107.3.5 - Minimum plan review criteria for buildings. -  
Please provide a floor plan showing location of proposed door replacement.

Correction Comment 2: FBC-B 7th 2020 1609.1 - Wind Loads - Applications - Buildings, structures and parts thereof shall be designed to withstand the minimum wind loads prescribed herein.  
Provide the Design Pressures for the openings in the building. Only pressures for product provided.

**ATTENTION:**

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will become Void as per **Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4 (as amended)**.