

**COLLIER COUNTY GOVERNMENT**  
**GROWTH MANAGEMENT DEPARTMENT / BUILDING REVIEW & INSPECTION DIVISION**  
2800 N. Horseshoe Drive, Naples FL 34104 \* Phone (239) 252-2428

## Outstanding Corrections

**Date:** March 13, 2023  
**Contact Name:** Diane Baldrich  
**Address:** 1210 Golden Gate BLVD East  
**City, State Zip:** Naples, FL 34120

**PERMIT NO:** PRCP2023020473101  
**APPLICATION NO:** PRCP20230204731  
**JOB SITE ADDRESS:** 13375 Snook CIR,  
(Mobile/Modular) , Naples  
**Email:** dbaldrich6@aol.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

***For Applications Submitted through the GMD E-Permitting Portal:***

- Resubmittals must be submitted in the same session and the changes must be clouded.
- Corrected documents must be submitted as complete files (with the corrected sheets *replacing* the rejected sheets). Submittals containing just the corrected sheets will be returned as Insufficient.
- **A written letter of response summarizing the changes made to address each correction comment must be included in your resubmittal. Failure to include a written letter of response will result in a rejection.**
- After your resubmittal is processed the documents will be reviewed again; additional deficiencies may be identified through this process.

**JOB DESCRIPTION:** Installing a casita with covered porch  
13375 Snook CIR, (Mobile/Modular) , Naples

**Rejected Review: Residential Review**

**Reviewed By: Robert Moore**

**Phone: 239-252-5705    Email: Robert.Moore@colliercountyfl.gov**

Correction Comment 1: FBC-B 7th 2020 107.3.5 - Minimum plan review criteria for buildings.

1. Please provide structural plans.

Correction Comment 2: FBC-EC 7th 2020 R101.5 - Compliance - Residential buildings shall meet the provisions of the Florida Building Code, Energy Conservation-Residential Provisions.

1. Please provide energy calculations.

Correction Comment 3: As required by Florida Statute 553.842 and Florida Administrative Code 9B-72, please provide the Florida State Product Approval or Miami-Dade Notice of Acceptance for the building components.

Please provide an index sheet listing all products being used including:

1. Roof underlayment.

Correction Comment 4: FBC-R Chapter 7 Wall Covering

R703.7.3 Water-Resistive Barriers.

2 layers of grade D paper required for stucco on wood-based sheathing.

**ATTENTION:**

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will become Void as per **Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4 (as amended)**.