



Nick Walters, P.E.

Project Manager

ATWELL, LLC

239.405.7777 Office

239.580.7768 Mobile

28100 Bonita Grande Dr | Suite 305 | Bonita Springs, FL 34135

www.atwell-group.com

January 10, 2023

RE: Flow Test for Deferral – Rivergrass North

To whom it may concern,

I am in receipt of your request to defer to a later date the requirements for a fire flow test at Rivergrass North Village. I am **granting** this request to defer to a later date such requirements based on the informational report that was conducted by Collier County Utilities and is on file with Rivergrass Villages submittal package and the agreement with Rivergrass Villages. This agreement was signed by Collier County Board of Commissioners on June 8th, 2021.

The Rivergrass North Village project is located over 2 miles from the nearest fire hydrants development. The fire hydrants in that community are fed from Collier County Utilities and any tests on those hydrants would not be relevant to this proposed project

The Rivergrass North Village fire flow design, was modeled with the watermain residual pressures at 60 psi at our point of connection to the transmission main that CCU is currently installing from the CCU Orange Tree facility to the future Rivergrass North and South development. The 60 psi residual pressure is based on the design team at Collier County Utilities in conjunction with Agnoli Barber & Brundage, Inc. engineer firm.

Sean Lintz

Battalion Chief of Life Safety/Fire Marshal

North Collier Fire Control and Rescue District

6495 Taylor Road

Naples, FL 34109

239-597-9227

<https://northcollierfire.com>

NORTH COLLIER FIRE CONTROL AND RESCUE DISTRICT

LIFE SAFETY & FIRE PREVENTION

6495 Taylor Road Naples, FL 34109 ■ (239) 597-9227 ■ northcollierfire.com